



# ENGINE GOVERNING SYSTEMS

SERVICE BULLETIN

Section EG 110-2

## SUBJECT

Obsolescence of AGD 100 A1 and AGD 100 A2 Electric Actuators

The above mentioned electric governor fuel metering actuator has been superseded since 6-24-74 by AGD 130E series electric actuators. It will be permanently removed from the product line and can be replaced when service requirements develop by the AGD 130 E4 actuator. The AGD 130 E4 actuator is a direct service replacement for the subject actuators when utilized on 12 or 24 VDC applications.

There are no wiring or plumbing changes required.